

Information sheet (Lot.10)

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011.
Information to identify the model(s) to which the information relates to:

AIR CONDITIONER
TYPE : MULTI SPLIT
WALL MOUNTED
Indoor unit(s) : ASEH07KMCG x 5
Outdoor unit : AOE36KBTA5
BRAND : FUJITSU

N/A = Not Applicable

Function			
Cooling	Yes	Average	Yes
Heating	Yes	Warmer	No
		Colder	No

Design load				Seasonal efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Cooling	Pdesignc	9.5	kW	Cooling	SEER	8.50	-
Heating/Average	Pdesignh	7.0	kW	Heating/Average	SCOP/A	4.60	-
Heating/Warmer	Pdesignh	N/A	kW	Heating/Warmer	SCOP/W	N/A	-
Heating/Colder	Pdesignh	N/A	kW	Heating/Colder	SCOP/C	N/A	-

Cooling							
Declared capacity for cooling, at indoor temperature 27 (19) °C and outdoor temperature Tj				Declared energy efficiency ratio, at indoor temperature 27 (19) °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 35°C	Pdc	9.50	kW	Tj = 35°C	EER d	3.80	-
Tj = 30°C	Pdc	7.00	kW	Tj = 30°C	EER d	5.84	-
Tj = 25°C	Pdc	4.50	kW	Tj = 25°C	EER d	10.31	-
Tj = 20°C	Pdc	2.08	kW	Tj = 20°C	EER d	17.11	-

Heating/Average							
Declared capacity for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	6.19	kW	Tj = -7°C	COPd	3.01	-
Tj = 2°C	Pdh	3.77	kW	Tj = 2°C	COPd	4.72	-
Tj = 7°C	Pdh	4.06	kW	Tj = 7°C	COPd	6.11	-
Tj = 12°C	Pdh	3.89	kW	Tj = 12°C	COPd	7.71	-
Tj = bivalent temperature	Pdh	6.19	kW	Tj = bivalent temperature	COPd	3.01	-
Tj = operating limit*	Pdh	5.85	kW	Tj = operating limit*	COPd	2.96	-

Heating/Warmer							
Declared capacity for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COPd	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COPd	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COPd	N/A	-
Tj = operating limit*	Pdh	N/A	kW	Tj = operating limit*	COPd	N/A	-

Heating/Colder							
Declared capacity for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = -7°C	Pdh	N/A	kW	Tj = -7°C	COPd	N/A	-
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COP d	N/A	-
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COP d	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COP d	N/A	-
Tj = operating limit*	Pdh	N/A	kW	Tj = operating limit*	COP d	N/A	-
Tj=-15°C	Pdh	N/A	kW	Tj = -15°C	COP d	N/A	-

Bivalent temperature				Operating limit temperature			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Heating/Average	Tbiv	-7	°C	Heating/Average	Tol	-15	°C
Heating/Warmer	Tbiv	N/A	°C	Heating/Warmer	Tol	N/A	°C
Heating/Colder	Tbiv	N/A	°C	Heating/Colder	Tol	N/A	°C

Cycling interval capacity				Cycling interval efficiency			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
For cooling	Pcycc	N/A	kW	For cooling	EERcyc	N/A	-
For heating	Pcyh	N/A	kW	For heating	COPcyc	N/A	-
Degradation coefficient cooling	Cdc	0.25	-	Degradation coefficient heating	Cdh	0.25	-

Electric power input in power modes other than 'active mode'				Annual electricity consumption			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Off mode (Cooling/Heating)	P _{OFF}	5.0/5.0	W	Cooling	Q _{CE}	391	kWh/a
Standby mode (Cooling/Heating)	P _{SB}	5.0/5.0	W	Heating/Average	Q _{HE}	2126	kWh/a
Thermostat-off mode (Cooling/Heating)	P _{TO}	11.0/23.0	W	Heating/Warmer	Q _{HE}	N/A	kWh/a
Crankcase heater mode (Cooling/Heating)	P _{CK}	0.0/0.0	W	Heating/Colder	Q _{HE}	N/A	kWh/a

Capacity control		Other items		
Item	Y/N	Item	Symbol	Value Unit
Fixed	No	Sound power level (Indoor/Outdoor)	L _{WA}	54.0/65.0 dB(A)
Staged	No	Global warming potential	GWP	675 kgCO ₂ eq.
Variable	Yes	Rated air flow (Indoor/Outdoor)	-	650/2450 m ³ /h

Contact details for obtaining more information	FUJITSU GENERAL LIMITED 3-3-17, Suenaga, Takatsu-ku, Kawasaki, 213-8502, Japan
--	---

* : Temperature at part load E condition(EN 14825)

V20121214

Information of indoor unit combination

Indoor unit combination (all indoor unit WALL MOUNTED KG/KM/KE type only)

N/A = Not Applicable

Combination of indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load Pdesignc	Seasonal efficiency SEER	Annual electricity consumption QcWh/a	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOPIA	Annual electricity consumption QhWh/a	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOPIW	Annual electricity consumption QhWh/a	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOPIc	Annual electricity consumption QhWh/a	Energy efficiency class
					kW		Wh/a		kW		Wh/a		kW		Wh/a		kW		Wh/a	
07	24	-	-	-	9.0	7.9	399	A++	7.0	4.3	2279	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	-	8.5	7.9	377	A++	6.8	4.3	2214	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	-	9.5	7.8	426	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	-	8.0	8.2	341	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	-	8.0	8.2	341	A++	6.5	4.5	2022	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	-	8.5	8.1	367	A++	6.8	4.4	2164	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	-	7.5	8.2	320	A++	6.0	4.5	1987	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	-	8.5	8.1	367	A++	6.8	4.4	2164	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	-	9.0	8.1	389	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED KG/KM/KE type only)

N/A = Not Applicable

Combination of Indoor unit ¹					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load Pdesignc	Seasonal efficiency SEER	Annual electricity consumption Q _{CE}	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOP/A	Annual electricity consumption Q _{HE}	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOPW	Annual electricity consumption Q _{HE}	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOP/C	Annual electricity consumption Q _{HE}	Energy efficiency class
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	18	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	14	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	22	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	14	24	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	18	-	-	9.5	8.0	416	A++	7.0	4.4	2227	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	-	8.0	8.5	329	A+++	6.5	4.6	1978	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	-	8.5	8.4	354	A++	6.8	4.5	2116	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	-	9.0	8.4	375	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

¹

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED KG/KM/KE type only)

N/A = Not Applicable

Combination of Indoor unit ¹					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load Pdesignc	Seasonal efficiency SEER	Annual electricity consumption Q _{CE}	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOP/A	Annual electricity consumption Q _{HE}	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOPW	Annual electricity consumption Q _{HE}	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOP/C	Annual electricity consumption Q _{HE}	Energy efficiency class
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	07	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	22	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

¹

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED KG/KM/KE type only)

N/A = Not Applicable

Combination of Indoor unit ¹					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load Pdesigng	Seasonal efficiency SEER	Annual electricity consumption Q _{CE}	Energy efficiency class	Design load Pdesigng	Seasonal efficiency SCOP/A	Annual electricity consumption Q _{HE}	Energy efficiency class	Design load Pdesigng	Seasonal efficiency SCOPW	Annual electricity consumption Q _{HE}	Energy efficiency class	Design load Pdesigng	Seasonal efficiency SCOP/C	Annual electricity consumption Q _{HE}	Energy efficiency class
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
09	09	12	24	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	12	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	12	18	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	12	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	14	14	14	-	9.5	8.3	401	A++	7.0	4.5	2178	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	07	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	22	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	07	24	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	22	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	09	24	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	12	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	07	14	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	22	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	12	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	09	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

¹

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (all indoor unit WALL MOUNTED KG/KM/KE type only)

N/A = Not Applicable

Combination of Indoor unit *1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesignc	SEER	Q _{CE}		Pdesignh	SCOP/A	Q _{HE}		Pdesignh	SCOPW	Q _{HE}		Pdesignh	SCOP/C	Q _{HE}	
					kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-	kW	-	kWh/a	-
07	07	12	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	09	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	18	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	14	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	12	9.5	8.5	391	A+++	7.0	4.6	2130	A++	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Indoor unit combination (except all indoor unit WALL MOUNTED KG/KMKE type)

N/A = Not Applicable

Combination of indoor unit 1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load Pdesignc	Seasonal efficiency SEER	Annual electricity consumption Q _{CE}	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOP/A	Annual electricity consumption Q _{HE}	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOPW	Annual electricity consumption Q _{HE}	Energy efficiency class	Design load Pdesignh	Seasonal efficiency SCOP/C	Annual electricity consumption Q _{HE}	Energy efficiency class
					KW		KWh/a		KW		KWh/a		KW		KWh/a		KW		KWh/a	
05	22	-	-	-	7.5	6.1	430	A++	6.0	4.1	2380	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	24	-	-	-	8.5	6.0	496	A+	6.8	4.0	2380	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	24	-	-	-	9.0	6.0	525	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	22	-	-	-	8.5	6.0	496	A+	6.8	4.0	2380	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	18	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	22	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24	24	-	-	-	9.5	6.0	554	A+	7.0	4.0	2450	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	18	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	22	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	05	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	18	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	07	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	14	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	18	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	09	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	12	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	14	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	12	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	14	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	18	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	22	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	22	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
05	24	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	-	-	8.0	6.3	444	A++	6.5	4.2	2167	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	18	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	-	-	7.5	6.3	417	A++	6.0	4.2	2000	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	-	-	8.5	6.2	480	A++	6.8	4.1	2322	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	14	-	-	9.0	6.2	508	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	18	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	22	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	24	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	12	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	12	14	-	-	9.5	6.1	545	A++	7.0	4.1	2390	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

05 = 5000Btu/h class = 1.5kW class

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

N/A = Not Applicable

*1

05 =	5000Btu/h class = 1.5kW class
07 =	7000Btu/h class = 2.0kW class
09 =	9000Btu/h class = 2.5kW class
12 =	12000Btu/h class = 3.5kW class
14 =	14000Btu/h class = 4.0kW class
18 =	18000Btu/h class = 5.0kW class
22 =	22000Btu/h class = 6.0kW class
24 =	24000Btu/h class = 7.0kW class

Indoor unit combination (except all indoor unit WALL MOUNTED KG/KMKE type)

N/A = Not Applicable

Combination of indoor unit 1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesignc	SEER	Q _{CE}		Pdesignh	SCOP/A	Q _{HE}		Pdesignh	SCOPW	Q _{HE}		Pdesignh	SCOP/C	Q _{HE}	
					KW	-	KWh/a	-	KW	-	KWh/a	-	KW	-	KWh/a	-	KW	-	KWh/a	-
07	07	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	14	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	18	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	14	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	18	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	12	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	14	14	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	24	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	14	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	18	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	22	-	9.5	6.3	528	A++	7.0	4.2	2333	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

**1

05 = 5000Btu/h class = 1.5kW class

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

N/A = Not Applicable

[illegible]

*1	*2
05 = 5000Btu/h class = 1.5kW class 07 = 7000Btu/h class = 2.0kW class 09 = 9000Btu/h class = 2.5kW class 12 = 12000Btu/h class = 3.5kW class 14 = 14000Btu/h class = 4.0kW class 18 = 18000Btu/h class = 5.0kW class 22 = 22000Btu/h class = 6.0kW class 24 = 24000Btu/h class = 7.0kW class	As for the 22 model, WALL MOUNTED type indoor unit is only connectable.

Indoor unit combination (except all indoor unit WALL MOUNTED KG/KMKE type)

N/A = Not Applicable

Combination of indoor unit 1					Cooling				Heating/Average				Heating/Warmer				Heating/Colder			
room1	room2	room3	room4	room5	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class	Design load	Seasonal efficiency	Annual electricity consumption	Energy efficiency class
					Pdesign _g	SEER	Q _{CE}		Pdesign _h	SCOP _A	Q _{HE}		Pdesign _h	SCOP _W	Q _{HE}		Pdesign _h	SCOP _C	Q _{HE}	
					KW	-	KWh/a	-	KW	-	KWh/a	-	KW	-	KWh/a	-	KW	-	KWh/a	-
07	07	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	07	12	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	09	14	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
07	09	12	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	09	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	09	18	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	09	12	14	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
09	09	12	12	12	9.5	6.5	512	A++	7.0	4.3	2276	A+	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

*1

05 = 5000Btu/h class = 1.5kW class

07 = 7000Btu/h class = 2.0kW class

09 = 9000Btu/h class = 2.5kW class

12 = 12000Btu/h class = 3.5kW class

14 = 14000Btu/h class = 4.0kW class

18 = 18000Btu/h class = 5.0kW class

22 = 22000Btu/h class = 6.0kW class

24 = 24000Btu/h class = 7.0kW class

Information of unit specification

Model Type	Model No.	Capacity Class	Dimension [H x W x D]	Sound power level(Cooling)	Sound power level(Heating)
		kW	mm	dB(A)	dB(A)
OUTDOOR	AOEG36KBTAS	-	884 x 820 x 315	65	68
WALL MOUNTED	ASEH05KJCAL ASEH05KJCALB	1.5	270 x 798 x 240	50	50
	ASEH07KJCAL ASEH07KJCALB	2.0		51	51
	ASEH09KJCAL ASEH09KJCALB	2.5		55	56
	ASEH12KJCAL ASEH12KJCALB	3.5		56	56
	ASEH14KJCAL ASEH14KJCALB	4.0		59	59
	ASEH05KNCA	1.5	270 x 784 x 222	50	50
	ASEH07KNCA	2.0		51	51
	ASEH09KNCA	2.5		56	56
	ASEH12KNCA	3.5		57	57
	ASYG07KMCF ASEH07KMCG ASEH07KMCG-B	2.0	270 x 834 x 222	54	56
	ASYG09KMCF ASEH09KMCG ASEH09KMCG-B	2.5		55	57
	ASYG12KMCF ASEH12KMCG ASEH12KMCG-B	3.5		55	58
	ASYG14KMCF ASEH14KMCG ASEH14KMCG-B	4.0		57	59
	ASYG07KGTG ASEH07KGTG	2.0	270 x 834 x 215	54	56
	ASYG09KGTG ASEH09KGTG	2.5		55	57
	ASYG12KGTG ASEH12KGTG	3.5		56	58
	ASYG14KGTG ASEH14KGTG	4.0		57	59
	ASYG18KMTE ASEG18KMTE	5.0	280 x 980 x 240	60	61
	ASYG22KMTE ASEG22KMTE	6.0		62	62
	ASYG24KMTE ASEG24KMTE	7.0		65	65
	ASYG07KETF ASEG07KETF ASYG07KETF-B ASEG07KETF-B	2.0	295 x 950 x 230	54	56
	ASYG09KETF ASEG09KETF ASYG09KETF-B ASEG09KETF-B	2.5		55	57
	ASYG12KETF ASEG12KETF ASYG12KETF-B ASEG12KETF-B	3.5		55	58
	ASYG14KETF ASEG14KETF ASYG14KETF-B ASEG14KETFB	4.0		57	59
CASSETTE	AUXG07KVLA	2.0	245 x 570 x 570 (Panel: 49 x 620 x 620)	46	47
	AUXG09KVLA	2.5		46	47
	AUXG12KVLA	3.5		49	49
	AUXG14KVLA	4.0		50	55
	AUXG18KVLA	5.0		50	55
	AUXG22KVLA	6.0		56	57
DUCT	ARXG07KSLAP	2.0	198 x 700 x 450	52	53
	ARXG09KSLAP	2.5		54	56
	ARXG12KSLAP	3.5		55	57
	ARXG14KSLAP	4.0		60	62
	ARXG18KSLAP	5.0	198 x 900 x 450	58	59
	ARXG07KLLAP	2.0	198 x 700 x 620	57	57
	ARXG09KLLAP	2.5		57	57
	ARXG12KLLAP	3.5		58	58
	ARXG14KLLAP	4.0		60	60
	ARXG18KLLAP	5.0	198 x 900 x 620	58	58
	ARXG22KMLB	6.0	270 x 1135 x 700	60	62
	ARXH12KMTAP	3.5	240 x 700 x 700	58	58
	ARXH14KMTAP	4.0		59	59
	ARXH18KMTAP	5.0		60	60
	ARXH22KMTAP	6.0	240 x 1000 x 700	58	58
FLOOR	AGYG09KVCA AGEG09KVCA	2.5	600 x 740 x 200	52	52
	AGYG12KVCA AGEG12KVCA	3.5		55	55
	AGYG14KVCA AGEG14KVCA	4.0		56	56
	ABYG18KRTA ABEG18KRTA	5.0	235 x 1080 x 705	53	53
CEILING	ABYG22KRTA ABEG22KRTA	6.0		57	57